

# The Water We Drink



**Reedsburg Utility Commission**



# 2022

**Consumer Confidence Report**

Issued May 2023 | [www.reedsburgutility.com](http://www.reedsburgutility.com)

Reedsburg Utility Commission (RUC) wants you, our valued customer, to be confident the drinking water RUC serves is safe. This annual water quality report provides important information about where your water comes from and the test results used to ensure your tap water is safe and healthy to drink.

# INSIDE

Page 3

Regulations  
Education Information  
Sources of Water

Page 4

Health Information  
Lead in Drinking Water  
Detected Contaminants

Page 5

Inorganic Contaminants

Page 6

Radioactive Contaminants  
Disinfection Byproducts  
Additional Chemical Analyses

Page 7

PFAS Contaminants  
RUC Continuing Commitment

Page 8

Definition of Terms

## Our Mission

The Reedsburg Utility Commission shall provide safe, reliable, competitively priced, hometown services that help make this community a desirable place to live and do business.



## The Water We Drink 2022 Consumer Confidence Report

Dear Reedsburg Utility Commission Water Customer,

It is my pleasure to present Reedsburg Utility Commission's annual water quality report. This report is designed to inform you about the quality water and services we deliver to you every day. Our water source is five ground water wells. Our constant goal is to provide you with a safe and dependable supply of drinking water. I'm please to report that our drinking water is safe and meets Federal and State requirements.

Reedsburg Water Utility routinely monitors for constituents in your drinking water according to Federal and State laws. The tables enclosed in this report share the results of our monitoring for the period of January 1<sup>st</sup> through December 31<sup>st</sup>, 2022. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

We at the Reedsburg Water Utility work around the clock to provide top quality water to every tap. We ask that all our customers help protect our water sources, which are the heart of the community, our way of life, and our children's future.

We want our valued customers to be informed about their water utility. If you want to learn more, please attend one of our regularly scheduled meetings. They are held on the 3rd Monday of each month at 4 p.m. at 501 Utility Court, Reedsburg, WI.

I strongly encourage you to read this report. Additional copies are available online at [www.ReedsburgUtility.com](http://www.ReedsburgUtility.com) or at our office. If you have any questions, please feel free to contact me at (608)524-4381.

Sincerely,

A handwritten signature in black ink that reads 'Jon Craker'.

Jon Craker  
Water Supervisor  
Reedsburg Utility Commission



This report contains important and useful information about the sources, quality, and safety of your drinking water and describes how Reedsburg Water Utility meets all drinking water standards set by State and Federal governments.

## Our Local Water Supply

The Reedsburg Water Utility is made up of and maintains:

- Five well sites throughout the city
- Two pressure zones
- About 66 miles of water mains
- 629 hydrants
- 3,350 services

### Well # 8

Located by Reedsburg Area High School



## About Regulations

To ensure tap water is safe to drink, the Environmental Protection Agency (EPA) and the Food & Drug Administration (FDA) established regulations that limit the amount of certain contaminants in water provided by the water utility. Regulations also establish limits for contaminants in bottled water that provide

## Education Information

The sources of drinking water, both tap water and bottled water, include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive materials, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include:

**MICROBIAL CONTAMINANTS** such as viruses and bacteria, may come from sewage treatment plants, septic systems, agricultural livestock and wildlife.

**INORGANIC CONTAMINANTS** such as salts and metals, can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.

**ORGANIC CHEMICAL CONTAMINANTS** including synthetic and volatile organic chemicals may be by-products of industrial processes or petroleum production, and can also come from gas stations, urban storm water runoff, agricultural application and septic systems.

**PESTICIDES AND HERBICIDES** may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.

**RADIOACTIVE CONTAMINANTS** can be naturally-occurring or be the result of oil and gas production and mining activities.

## Sources of Water

Source ID	Source	Depth (in feet)	Status
3	Groundwater	490	Active
4	Groundwater	400	Active
6	Groundwater	310	Active
7	Groundwater	515	Active
8	Groundwater	500	Active



## Health Information

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's safe drinking water hotline at: (800) 426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbial contaminants are available from the EPA's safe drinking water hotline.

Nitrate in drinking water at levels above 10ppm is a health risk for infants of less than 6 months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask for advice from your health care provider.

Our water system did not monitor for cryptosporidium or radon during 2022. We are not required by state or federal drinking water regulation to do so.

We currently add chlorine as a disinfectant, fluoride to promote healthy development of teeth, and phosphate for lead and copper control.

---

## Lead in Drinking Water

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Reedsburg Utility Commission is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, test methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov](http://www.epa.gov).

## Detected Contaminants

Your water was tested for many contaminants last year. We are allowed to monitor for some contaminants less frequently than once a year. The following tables list only those contaminants which were detected in your water. If a contaminant was detected last year, it will appear in the following tables without a sample date. If the contaminant was not monitored last year, but was detected within the last 5 years, it will appear in the tables below along with the sample date.



# Inorganic Contaminants

Contaminant	MCL	MCLG	Level Found	Range	Last Year Sampled	Violation	Typical Source
BARIUM (ppm)	2	2	.013	.008-.022	2020	No	Discharge of drilling wastes, discharge from metal refineries, erosion of natural deposits
COPPER (ppm)	AL=1.3	1.3	.692 at the 90th percentile level	0 of 20 Results were above the action level	2020	No	Corrosions of household plumbing systems, erosions of natural deposits, leaching from wood preservatives.
FLUORIDE (ppm)	4	4	.70	.66-.74	2020	No	Erosion of natural deposits, water additive which promotes strong teeth, discharge from fertilizer and aluminum factories
LEAD (ppb)	AL=15	0	.84 at the 90th percentile level	1 of 20 Results were above the action level	2020	No	Corrosion of household plumbing systems, erosion of natural deposits
NITRATE (NO3-N) (ppm)	10	10	4.5	3.12-4.50	2022	No	Runoff from fertilizer use, leaching from septic tanks, sewage, erosion from natural deposits
SELENIUM (ppb)	50	50	<.8	<.8	2020	No	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines
SODIUM (ppm)	n/a	n/a	8.8	3.6-19.6	2020	No	n/a
ARSENIC (ppb)	10	n/a	.7	.5-.9	2020	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
CHROMIUM (ppb)	100	100	<5.3	<5.3	2020	No	Discharge from steel and pulp mills; Erosion of natural deposits.
MERCURY (ppb)	2	2	<.2	<.2	2020	No	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills; Runoff from crop land

“Reedsburg Water Utility is committed to providing an adequate supply of high quality water at a reasonable cost to the residents and businesses of Reedsburg. We are dedicated to supplying friendly, convenient and dependable service.”

## Radioactive Contaminants

Contaminant	MCL	MCLG	Level Found	Range	Last Year Sampled	Violation	Typical Source
GROSS, ALPHA, EXCL R & U (pCi/l)	15	0	2.04	<1.7 - 4.1	2020	No	Erosion of natural deposits
Combined Radium (pCi/l)	5	0	2.1	.92 - 3.4	2020	No	Erosion of natural deposits
GROSS, ALPHA, INCL R & U (pCi/l)	n/a	n/a	1.7	.2 - 4.2	2020	No	Erosion of natural deposits
Combined Uranium (ug/l)	30	0	.12	.1 - .2	2020	No	Erosion of natural deposits

## Disinfection Byproducts

Contaminant	MCL	MCLG	Level Found	Range	Last Year Sampled	Violation	Typical Source
HAA5 (ppb)	60	60	0	0	2022	No	By-products of drinking water disinfection
TTHM (ppb)	80	n/a	8.5	8.5	2022	No	By-products of drinking water disinfection

## Additional Chemical Analyses

Chemical	Level	Range
ALKALINITY Total (ppm)	144 avg.	100-200 Ideal
HARDNESS Total (ppm)	160 avg.	100-200 Ideal
pH Value (lab)	7.2 avg.	7-8.5 Ideal

## PFAS Contaminants with a Recommended Health Advisory Level

Perfluoroalkyl and polyfluoroalkyl substances (PFAS) are a large group of human-made chemicals that have been used in industry and consumer products worldwide since the 1950s. The following table list PFAS contaminants which were detected in your water and that have a Recommended Public Health Groundwater Standard (RPHGS) or Health Advisory Level (HAL). There are no violations for detections of contaminants that exceed the RPHGS or HAL. The RPHGS are levels at which concentrations of the contaminant present a health risk and are based on guidance provided by the Wisconsin Department of Health Services.

Contaminant (units)	RPHGS or HAL (PPT)	Level Found	Range	Sample Date
PFHXS (ppt)	40	2.30	0.00-2.30	2022



### Our Continuing Commitment

**Reedsburg Utility Commission and its trained , certified water quality professionals are committed to...**

- Providing high quality, safe drinking water at the lowest price possible
- Monitoring and testing the water we serve to optimize quality and ensure it's always safe
- Working around the clock to provide top quality water to every tap

On average, over 1,300 water quality samples were taken from our system throughout this past year. All samples were submitted and all results were safe.

# DEFINITION OF TERMS

<b>AL</b>	<b>Action Level</b> The concentration of a contaminant which, if exceeded, triggers treatment of other requirements which a water system must follow.	<b>n/d</b>	<b>Not Detected</b>
		<b>NTU</b>	<b>Nephelometric Turbidity Units</b>
		<b>pCi/l</b>	<b>Picocuries per liter</b> A measure of radioactivity.
<b>MCL</b>	<b>Maximum Contaminant Level</b> The highest level on a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.	<b>ppm</b>	<b>Parts Per Million</b> Milligrams per liter (mg/l).
		<b>ppb</b>	<b>Parts Per Billion</b> Micrograms per liter (ug/l)
<b>MCLG</b>	<b>Maximum Contaminant Level Goal</b> The level of a contaminant in drinking water below which is no known or expected risk to health. MCLGs all for a margin of safety.	<b>ppt</b>	<b>Parts Per Trillion</b> Nanograms per liter
		<b>ppq</b>	<b>Parts Per Quadrillion</b> Pictograms per liter
<b>MFL</b>	<b>Millions fibers per liter</b>	<b>TCR</b>	<b>Total Coliform Rule</b>
<b>mrem/yr</b>	<b>Millirems per year</b> A measure of radiation absorbed by the body.	<b>TT</b>	<b>Treatment Technique</b> A required process intended to reduce the level of contaminant in drinking water.
<b>n/a</b>	<b>not applicable</b>		