



Wisconsin State Laboratory of Hygiene  
 2601 Agriculture Drive, PO Box 7996  
 Madison, WI 53707-7996  
 (800)442-4618 - FAX (608)224-6213  
<http://www.slh.wisc.edu>

# Laboratory Report

Environmental Health Division

## WSLH Sample: 623590001

Report To:  
 JON CRAKER  
 PO BOX 230  
 501 UTILITY CT.  
 REEDSBURG, WI 53959

Invoice To:  
 JON CRAKER  
 PO BOX 230  
 501 UTILITY CT.  
 REEDSBURG, WI 53959  
 Customer ID: 15701026

System Name: REEDSBURG WATERWORKS  
 City: REEDSBURG  
 Collection Date/Time: 06/07/2022 11:30  
 Collected By: JON CRAKER  
 County: 57 - Sauk  
 Source Code: E - Entry Point  
 Collection Address: 1102 HWY 23  
 Location of Sample: ENTRY POINT

Monitor Point ID: W-8  
 PWS ID#: 15701026  
 WI Unique Well#: WP561  
 Entry Point ID: 8  
 Date Received: 6/7/2022  
 Date Reported: 6/24/2022  
 Sample Type: I-Investigation

### PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 06/13/22 12:15		Analysis Date: 06/14/22 17:20			
PFBS (375-73-5)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFHxA (307-24-4)	EPA Method 537.1	<1.90	ng/L	1.90	1.90
HFPO-DA (13252-13-6)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFHpA (375-85-9)	EPA Method 537.1	<1.90	ng/L	1.90	1.90
PFHxS (355-46-4)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
DONA (919005-14-4)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFNA (375-95-1)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFOS (1763-23-1)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
9CI-PF3ONS (756426-58-1)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFDA (335-76-2)	EPA Method 537.1	<1.90	ng/L	1.90	1.90
N-MeFOSAA (2355-31-9)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
N-EtFOSAA (2991-50-6)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFUnA (2058-94-8)	EPA Method 537.1	<1.90	ng/L	1.90	1.90
PFOA (335-67-1)	EPA Method 537.1	<1.90	ng/L	1.90	1.90
The matrix spike does not meet the upper QC limit.					
11CI-PF3OUdS (763051-92-9)	EPA Method 537.1	<0.948	ng/L	0.948	0.948
PFDoA (307-55-1)	EPA Method 537.1	<1.90	ng/L	1.90	1.90



Wisconsin State Laboratory of Hygiene  
2601 Agriculture Drive, PO Box 7996  
Madison, WI 53707-7996  
(800)442-4618 - FAX (608)224-6213  
<http://www.slh.wisc.edu>

# Laboratory Report

Environmental Health Division

**WSLH Sample: 623590001**

## PFAS in DW

Analyte	Analysis Method	Result	Units	LOD	LOQ
Prep Date: 06/13/22 12:15		Analysis Date: 06/14/22 17:20			
PFTrDA (72629-94-8)	EPA Method 537.1	<1.90	ng/L	1.90	1.90
PFTeDA (376-06-7)	EPA Method 537.1	<0.948	ng/L	0.948	0.948



Wisconsin State Laboratory of Hygiene  
2601 Agriculture Drive, PO Box 7996  
Madison, WI 53707-7996  
(800)442-4618 - FAX (608)224-6213  
<http://www.slh.wisc.edu>

# Laboratory Report

Environmental Health Division

**WSLH Sample: 623590001**

WDNR LAB ID:113133790    NELAP LAB ID:2091    EPA LAB ID:WI00007, WI00008    WI DATCP ID:105-415

## List of Abbreviations:

LOD = Level of detection  
LOQ = Level of quantification (for PFAS the LOQ = MRL)  
ND = None detected. Results are less than the LOD  
F next to result = Result is between LOD and LOQ  
Z next to result = Result is between 0 (zero) and LOD  
if LOD=LOQ, Limits were not statistically derived

Test results for NELAP accredited tests are certified to meet the requirements of the NELAC standards. For a list of accredited analytes

see <http://www.slh.wisc.edu/about/compliance/nelac-laboratory-accreditation>

Results, LOD and LOQ values have been adjusted for analytical dilutions and percent moisture where applicable.

Results relate only to the items tested.

This Laboratory Report shall not be reproduced except in full, without written approval of the laboratory.

The water microbiology unit analyzes samples as received and not all samples are tested for preservation before analysis is performed.

## Responsible Party

Inorganic Chemistry: Graham Anderson, Supervisor 608-224-6281  
Metals: Graham Anderson, Supervisor 608-224-6281  
Organics: Erin Mani, Supervisor 608-224-6269  
Environmental Toxicology: Dawn Perkins, Supervisor 608-224-6230  
Water Microbiology: Martin Collins, Supervisor 608-224-6239  
Radiochemistry: David Webb, Division Director 608-224-6227